



RECALL NOTICE:

ALERT!!!! Kidde recalls 5m disposable extinguishers



Product Safety Notice

Certain black plastic Zytel® nylon valve disposable fire extinguishers.

Not Affected:

- Professional Kidde and Badger Advantage models
- Fire Extinguishers Purchased Prior to August 2013 or After November 2014

Recall Summary

Name of Product: Items affected are Kidde brand, black plastic Zytel® nylon valve disposable extinguishers both ABC and BC rated models manufactured between July 23, 2013 and October 15, 2014 and sold between August 2013 and November 2014. The affected fire extinguishers are white or red in color and are either ABC or BC-rated. The Kidde logo and serial number are located on the nameplate. The date code is an ink jet 10-digit number stamped on the side of the cylinder near the bottom. Digits 5-9 of this number convey the day and year of manufacture. Affected units will have the following five digits in a date code:

2013: XXXX20413X through XXXX36513X
 2014: XXXX00114X through XXXX28814X

The models are as follows:

| | | | | | |
|------------|-----------|-----------|---------------|----------|-------------|
| 46-0066 | FC5 | KFH | ELITE 10 | FX210 | M5GM |
| 46-0092 | FH/ RESSP | M10G | ELITE 10 HOME | FX210R | MARINER 10 |
| AUTO FX11 | FS10 | M10GM | FA10G | FX210W | MARINER 110 |
| AUTO FX511 | FS110 | M110 | FA10T | FX340GW | MARINER 5 |
| BC5GD | FS5 | M110G | FA110 | FX340SC | MARINER 5 G |
| E10 | FULL HOME | 110M110GM | FA110G | FX340SCG | WMG10GM |
| E10H | FX10 | M5 | FA5 | FX511 | RESSP |
| E110 | FX10BC | M5C | FA5B | FX5II | XL 5MR |
| E5 | FX10K | M5G | FC10 | H110G | |
| FC110 | H5G | | | | |

Hazard: Kidde has identified a quality issue with black plastic Zytel® nylon valve disposable fire extinguishers. In a small number of instances, Kidde found that a supplier built a component that is out-of-specification. When the lever is pressed and released multiple times, the extinguisher may fail to fully discharge as designed.

Remedy: Replace

Kidde has posted a Public Safety Notice on their website that “certain black plastic Zytel® Nylon valve disposable fire extinguishers” are being recalled. The affected extinguishers are their ABC and BC rated models manufactured between July 23, 2013 and October 15, 2014. The state the affected fire extinguishers are white or red in color and the date code is an ink jet 10 digit number stamped on the side of the cylinder near the bottom.

The affected units will have the following five digits in a date code as follows:

2013: XXXX20413X through XXXX36513X

2014: XXXX00114X through XXXX28814X

They state that they have identified a quality issue with the black plastic valve of these disposable extinguishers. They further state that in a small number of instances they found that when the lever is pressed and released multiple times the extinguisher may fail to discharge as designed.

Direct anyone to the Kiddie website

<http://www.webfulfillment.com/StandardRegister/lpr.asp?l=614&ac=&ar=>

or the US consumer product safety commission site

<http://www.cpsc.gov/en/Recalls/2015/Kidde-Recalls-Disposable-Plastic-Fire-Extinguishers/>

For more information.
